

# MAINE STATE LEGISLATURE

The following document is provided by the  
**LAW AND LEGISLATIVE DIGITAL LIBRARY**  
at the Maine State Law and Legislative Reference Library  
<http://legislature.maine.gov/lawlib>



Reproduced from scanned originals with text recognition applied  
(searchable text may contain some errors and/or omissions)

STATE OF MAINE  
HOUSE OF REPRESENTATIVES  
100th LEGISLATURE

COMMITTEE AMENDMENT "A" to H. P. 1006, L. D. 1407, Bill, "An Act  
Relating to Exits in Buildings."

Amend said Bill in the title by striking out everything after  
the word "to" and inserting in place thereof the words and punctua-  
tion 'Fire Alarm Systems in Nursing Homes.'

Further amend said Bill by striking out all of the last  
underlined sentence and inserting in place thereof the following  
underlined sentence:

'Any building housing a nursing home or home for the aged having  
no more than 3 paid occupants shall be equipped with a heat  
activated fire alarm system approved by the Underwriters' Laborato-  
ries, Inc. or the Department of Industrial Cooperation of the Univer-  
sity of Maine.'

Reported by the Committee on Legal Affairs.

Reproduced and distributed under the direction of the Clerk of  
the House.

(Filing No. H-167)

4/7/61