

MAINE STATE LEGISLATURE

The following document is provided by the
LAW AND LEGISLATIVE DIGITAL LIBRARY
at the Maine State Law and Legislative Reference Library
<http://legislature.maine.gov/lawlib>



Reproduced from scanned originals with text recognition applied
(searchable text may contain some errors and/or omissions)

STATE OF MAINE
HOUSE OF REPRESENTATIVES
104th LEGISLATURE

COMMITTEE AMENDMENT " A " to H. P. 260, L. D. 336, Bill,
"AN ACT Relating to Installation of Sprinkler Systems in Hotels."

Amend said Bill in that part designated "§ 2463" by striking out all of the first underlined paragraph (same in L.D. 336) and inserting in place thereof the following underlined paragraph:

'All hotels or additions thereto constructed after January 1, 1970 of any type construction, other than fire resistive as defined in the current edition of National Fire Protection Association #220, Standard Types of Building Construction, having 3 stories or more above grade level, shall be protected by a complete approved automatic sprinkler system.'

Reported by the Committee on Business Legislation.

Reproduced and distributed under the direction of the Clerk of the House.

(Filing No. H-186)

4/16/69